



Jim Doyle, Governor
Mary P. Burke, Secretary

June 27, 2006

DENFELD CONSTRUCTION, INC.
MARK E. DENFELD
6702 CLOVER RD.
WAUSAU WI 54401-9251

Re: Description: SEWAGE TANK, SITE CONSTRUCTED
Manufacturer: DENFELD CONSTRUCTION, INC.
Product Name: HOLDING
Model Number(s): 4308, 4608, 4742, 5505, 6096, 10161
(4308 - 89.75 GAL/IN, 4608 - 69.82 GAL/IN, 4742 - 69.74 GAL/IN, 5505 - 79.78 GAL/IN,
6096 - 89.55 GAL/IN, 10161 - 149.43 GAL/IN, ALL TANKS -96" MAX. DEPTH OF BURY)
Product File No: 20060259

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This product is approved to use the following:
 - The inlet location may be lower than the listed liquid level specified for this product.
 - Optional EZ Set synthetic risers and riser covers.

This approval supersedes the approval issued on INSERT DATE under product file number 20050917

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050917.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov